



INSTYTUT TECHNIKI BUDOWLANEJ
PL 00-611 WARSZAWA
ul. Filtrowa 1
tel.: (+48 22) 825-04-71
(+48 22) 579-62-94
eta@itb.pl
www.itb.pl



Member of



www.eota.eu

European Technical Assessment

**ETA-12/0272
of 19/09/2022**

General Part

Technical Assessment Body issuing the European Technical Assessment

Instytut Techniki Budowlanej

Trade name of the construction product

KPR-FAST, KPS-FAST, KPR/FAST, KPS/FAST, KPR-STRONG and KPS-STRONG

Product family to which the construction product belongs

Plastic anchors for redundant non-structural systems in concrete and masonry

Manufacturer

KLIMAS Sp. z o.o.
ul. Wincentego Witosa 135/137
Kućnica Kiedrzyńska
PL 42-233 Mykanów
Poland

Manufacturing plant

Plant no 1, plant no 2
Poland

This European Technical Assessment contains

39 pages including 3 Annexes which form an integral part of this Assessment

This European Technical Assessment is issued in accordance with regulation (EU) No 305/2011, on the basis of

European Assessment Document EAD 330284-00-0604 "Plastic anchors for redundant non-structural systems in concrete and masonry"

This version replaces

ETA-12/0272 issued on 29/06/2018

This European Technical Assessment is issued by the Technical Assessment Body in its official language. Translations of this European Technical Assessment in other languages shall fully correspond to the original issued document and shall be identified as such.

Communication of this European Technical Assessment, including transmission by electronic means, shall be in full. However, partial reproduction may only be made with the written consent of the issuing Technical Assessment Body. Any partial reproduction has to be identified as such.

WWW.MADERASCAMACHO.ES

Specific Part

1 Technical description of the product

The KPR-FAST, KPS-FAST, KPR/FAST, KPS/FAST, KPR-STRONG and KPS-STRONG anchors consists of a plastic sleeve made of polyamide and an accompanying specific screw made of galvanised or stainless steel.

The plastic sleeve is expanded by screwing in the specific screw which presses the sleeve against the wall of the drilled hole.

The description of the products is given in Annex A.

2 Specification of the intended use in accordance with the applicable European Assessment Document (EAD)

The performance given in clause 3 are only valid if the anchor is used in compliance with the specifications and conditions given in Annex B.

The provisions made in this European Technical Assessment are based on an assumed working life of the anchor of 50 years. The indications given on the working life cannot be interpreted as a guarantee given by the producer or Technical Assessment Body, but are to be regarded only as a means for choosing the right products in relation to the expected economically reasonable working life of the works.

3 Performance of the product and references to the methods used for its assessment

3.1. Performance of the product

3.1.1. Safety in case of fire (BWR 2)

Essential characteristic	Performance
Reaction to fire	Anchorage satisfy requirements for Class A1
Resistance to fire	Annex C2

3.1.2. Safety and accessibility in use (BWR 4)

Essential characteristic	Performance
Resistance to steel failure under tension and shear loading	Annex C1
Resistance to pull-out or concrete failure under tension loading (base material group a)	Annex C2
Resistance in any load direction without lever arm (base material group b, c and d)	Annex C4
Edge distance and spacing	Annex B3, B4
Displacements under short-term and long-term loading	Annex C3, C5

3.1.3. Aspects of durability

Essential characteristic	Performance
Durability – corrosion of metal parts	- anchor sleeve – no metal parts - screw – see Annex A15 and B1
Durability – high alkalinity of plastic sleeve	no influence of high alkalinity

3.2 Methods used for the assessment

The assessment has been made in accordance with EAD 330284-00-0604.

4 Assessment and verification of constancy of performance (AVCP) system applied, with reference to its legal base

According to the Decision 97/463/EC of the Commission of 27 June 1997 the system 2+ of assessment and verification of constancy of performance (see Annex V to regulation (EU) No 305/2011) applies.


5 Technical details necessary for the implementation of the AVCP system, as provided in the applicable European Assessment Document (EAD)

Technical details necessary for the implementation of the AVCP system are laid down in the control plan deposited in Instytut Techniki Budowlanej.

For the type testing the results of the tests performed as part of the assessment for the European Technical Assessment shall be used unless there are changes in the production line or plant. In such cases the necessary type testing has to be agreed between Instytut Techniki Budowlanej and the notified body.

Issued in Warsaw on 19/09/2022 by Instytut Techniki Budowlanej


Krzysztof Kuczyński, PhD
Deputy Director of ITB



Intended Use

Fixing in concrete and in different types of masonry

Legend


- h_{nom} = overall plastic anchor embedment depth in the base material
 h_1 = depth of drill hole to deepest point
 h = thickness of member (wall)
 t_{fix} = t_{tol} + thickness of fixture
 t_{tol} = thickness of equalizing layer or non-load-bearing coating

**KPR-FAST, KPS-FAST, KPR/FAST, KPS/FAST,
KPR-STRONG and KPS-STRONG**


Product description
Intended use

Annex A1
of European
Technical Assessment
ETA-12/0272


Sleeve KPR



Screw KS



Screw KK




KPR-FAST, KPS-FAST, KPR/FAST, KPS/FAST,
KPR-STRONG and KPS-STRONG


Product description
KPR-FAST 8/50 and 8/70 anchors

Annex A2
of European
Technical Assessment
ETA-12/0272


Sleeve KPS



Screw KS



Screw KK




**KPR-FAST, KPS-FAST, KPR/FAST, KPS/FAST,
KPR-STRONG and KPS-STRONG**

Product description
KPS-FAST 8/50 and 8/70 anchors


Annex A3
of European
Technical Assessment
ETA-12/0272

Sleeve KPR




Marking of the producer, type, size, e.g.
WK, KPR-FAST, 10x100, colour red

Screw KSS



Screw KKS




KPR-FAST, KPS-FAST, KPR/FAST, KPS/FAST,
KPR-STRONG and KPS-STRONG

Product description
KPR-STRONG 10 anchors

Annex A4
of European
Technical Assessment
ETA-12/0272


Annex A5
of European
Technical Assessment
ETA-12/0272

Sleeve KPR




Marking of the producer, type, size, e.g.
WK, KPR/FAST, 10x100, colour grey

Screw KS



Screw KK




KPR-FAST, KPS-FAST, KPR/FAST, KPS/FAST,
KPR-STRONG and KPS-STRONG

Product description
KPR/FAST 10 anchors

Annex A6
of European
Technical Assessment
ETA-12/0272


Annex A7
of European
Technical Assessment
ETA-12/0272

Sleeve KPR




Marking of the producer, type, size, e.g.
KLIMAS, KPR-FAST, 10x100, colour grey

Screw KS



Screw KK




KPR-FAST, KPS-FAST, KPR/FAST, KPS/FAST,
KPR-STRONG and KPS-STRONG

Product description
KPR-FAST 10/50 and 10/70 anchors


Annex A8
of European
Technical Assessment
ETA-12/0272

Sleeve KPS




Marking of the producer, type, size, e.g.
KLIMAS, KPS-FAST, 10x100, colour grey

Šruba KS



Šruba KK




KPR-FAST, KPS-FAST, KPR/FAST, KPS/FAST,
KPR-STRONG and KPS-STRONG

Product description
KPS-FAST 10/50 and 10/70 anchors


Annex A9
of European
Technical Assessment
ETA-12/0272

Sleeve KPR




Marking of the producer, type, size, e.g.
WK, KPR-FAST, 12x100, colour grey

Screw KS



Screw KK




KPR-FAST, KPS-FAST, KPR/FAST, KPS/FAST,
KPR-STRONG and KPS-STRONG

Product description
KPR-FAST 12 anchors


Annex A10
of European
Technical Assessment
ETA-12/0272

Sleeve KPS




Marking of the producer, type, size, e.g.
WK, KPS-FAST, 12x100, colour grey

Screw KS



Screw KK




**KPR-FAST, KPS-FAST, KPR/FAST, KPS/FAST,
KPR-STRONG and KPS-STRONG**

Product description
KPS-FAST 12 anchors


Annex A11
of European
Technical Assessment
ETA-12/0272

Sleeve KPR




Marking of the producer, type, size, e.g.
WK, KPR-FAST, 14x100, colour grey

Screw KS



Screw KK




KPR-FAST, KPS-FAST, KPR/FAST, KPS/FAST,
KPR-STRONG and KPS-STRONG

Product description
KPR-FAST 14 anchors


Annex A12
of European
Technical Assessment
ETA-12/0272

Sleeve KPS




Marking of the producer, type, size, e.g.
WK, KPS-FAST, 14x100, colour grey

Screw KS



Screw KK



KPR-FAST, KPS-FAST, KPR/FAST, KPS/FAST,
KPR-STRONG and KPS-STRONG

Product description
KPS-FAST 14 anchors

Annex A13
of European
Technical Assessment
ETA-12/0272

Table A1: Anchor types and dimensions

Anchor type	Anchor sleeve ¹⁾					Screw ¹⁾				
	d _{nom} [mm]	d _{sf} [mm]	h _{nom} [mm]	l _{a, nom} [mm]	l _{sf} [mm]	d [mm]	l _{g, min} [mm]	l _{s, min} [mm]	d _p [mm]	
									KK KKS ²⁾	KS KSS ²⁾
KPR-FAST 8/50	8	15	50	60 - 220	2	6.0	50	l _{a, nom} + 5 mm	13	11
KPS-FAST 8/50	8	12	50	60 - 220	-	6.0	50	l _{a, nom} + 5 mm	13	11
KPR-FAST 8/70	8	15	70	80 - 220	2	6.0	70	l _{a, nom} + 5 mm	13	11
KPS-FAST 8/70	8	12	70	80 - 220	-	6.0	70	l _{a, nom} + 5 mm	13	11
KPR-STRONG 10 ²⁾	10	18	70	80 - 300	2	7.0	65	l _{a, nom} + 5 mm	18 ²⁾	14 ²⁾
KPS-STRONG 10 ²⁾	10	15	70	80 - 300	-	7.0	65	l _{a, nom} + 5 mm	18 ²⁾	14 ²⁾
KPR/FAST 10	10	18	70	80 - 300	2	7.0	65	l _{a, nom} + 5 mm	18	14
KPS/FAST 10	10	15	70	80 - 300	-	7.0	65	l _{a, nom} + 5 mm	18	14
KPR-FAST 10/50	10	18	50	60 - 300	2	7.0	50	l _{a, nom} + 5 mm	18	14
KPS-FAST 10/50	10	13	50	60 - 300	-	7.0	50	l _{a, nom} + 5 mm	18	14
KPR-FAST 10/70	10	18	70	80 - 300	2	7.0	70	l _{a, nom} + 5 mm	18	14
KPS-FAST 10/70	10	13	70	80 - 300	-	7.0	70	l _{a, nom} + 5 mm	18	14
KPR-FAST 12	12	18	70	80 - 360	2	8.0	70	l _{a, nom} + 5 mm	18	14
KPS-FAST 12	12	15	70	80 - 360	-	8.0	70	l _{a, nom} + 5 mm	18	14
KPR-FAST 14	14	22	70	80 - 360	2	10.0	60	l _{a, nom} + 10 mm	22	20
KPS-FAST 14	14	22	70	80 - 360	-	10.0	60	l _{a, nom} + 10 mm	22	20

¹⁾ the anchor (plastic sleeve and special screw) shall only be packaged and supplied as a complete unit

²⁾ with special screw KKS and KSS

**KPR-FAST, KPS-FAST, KPR/FAST, KPS/FAST,
KPR-STRONG and KPS-STRONG**

Product description
Anchor types and dimensions

Annex A14
of European
Technical Assessment
ETA-12/0272

Table A2: Materials

Element	Material		
	KPR-FAST 8 KPS-FAST 8 KPR/FAST 10 KPS/FAST 10 KPR-FAST 10 KPS-FAST 10	KPR-STRONG 10 KPS-STRONG 10	KPR-FAST 12 KPS-FAST 12 KPR-FAST 14 KPS-FAST 14
Anchor sleeve	polyamid, PA6, colour grey	polyamid, PA6, colour red	polyamid, PA6, colour grey
Specific screw	steel ($f_{y,k} \geq 480$ MPa, $f_{u,k} \geq 600$ MPa)		steel ($f_{y,k} \geq 320$ MPa, $f_{u,k} \geq 400$ MPa)
	a) electroplated coating ≥ 5 μm according to EN ISO 4042 or non-electrolytically applied zinc flake coating ≥ 5 μm according to EN ISO 10683; b) hot dip galvanised coating ≥ 40 μm according to EN ISO 10684; c) "SQ-ceramic" non-electrolytically applied zinc flake coating ≥ 10 μm according to EN ISO 10683; d) zinc diffusion coating ≥ 30 μm according to EN 13811 and EN ISO 17668		
	or stainless steel grade 1.4301, 1.4306, 1.4307, 1.4567 (AISI 304) or 1.4401, 1.4404, 1.4571, 1.4362, 1.4578 (AISI 316) according to EN 10088 ($f_{y,k} \geq 450$ MPa, $f_{u,k} \geq 580$ MPa)		

**KPR-FAST, KPS-FAST, KPR/FAST, KPS/FAST,
KPR-STRONG and KPS-STRONG**

Product description
Materials

Annex A15
of European
Technical Assessment
ETA-12/0272

Specification of intended use

Anchorage subject to:

- Static and quasi-static loads.
- Multiple fixing of non-structural applications.

Base materials:

- Reinforced or unreinforced normal weight concrete with strength classes $\geq$ C12/15 (base material group a), according to EN 206.
 - Thin-wall concrete elements, reinforced or unreinforced, with strength classes $\geq$ C16/20 and wall thickness $\geq$ 30 mm (base material group a).
 - Solid masonry (base material group b), according to Annex C3.
- Note: The characteristic resistance is also valid for larger sizes and larger compressive strength of the masonry unit.
- Hollow or perforated masonry (base material group c), according to Annex C3.
 - Autoclaved aerated concrete (base material group d), according to Annex C3.
 - Mortar strength class of the masonry M2.5 at minimum according to EN 998-2.
 - For other base materials of the base material group a, b, c and d the characteristic resistance of the anchor may be determined by job site tests according to TR 051:2018-04.

Temperature range:

- -20°C to +80°C (max. short term temperature +80°C and max. long term temperature +50°C).

Use conditions (environmental conditions):

- Structures subject to dry internal conditions (zinc coated steel, stainless steel).
- Structures subject to external atmospheric exposure, if anchor is not directly subjected to this exposure, i.e. external cladding elements screen the anchor, and the head of screw is additionally protected by permanently elastic coating which precludes corrosion from occurring and prevents moisture from entering into plastic sleeve (zinc coated steel).
- Structures subject to external atmospheric exposure including industrial and marine environment (stainless steel).
- Structures subject to permanently damp internal condition, if no particular aggressive conditions exist (stainless steel).

Note: Particular aggressive conditions are e.g. permanent, alternating immersion in seawater or the splash zone of seawater, chloride atmosphere of indoor swimming pools or atmosphere with extreme chemical pollution (e.g. in desulphurization plants or road tunnels where de-icing materials are used).

Design:

- The anchorages are designed in accordance with the TR 064:2018-05 under the responsibility of an engineer experienced in anchorages and masonry work.
- Verifiable calculation notes and drawings shall be prepared taking account the loads to be anchored, the nature and strength of the base materials and the dimensions of the anchorage members as well as of the relevant tolerances. The position of the anchor is indicated on the design drawings.
- Anchors are only to be used for multiple fixings for non-structural application, according to TR 064:2018-05.

Installation:

- Hole shall be drilled by the drill modes given in Annexes C2 and C3 for use categories a, b, c and d; the influence of other drilling methods may be determined by job site tests according to TR 051:2018-04.
- Anchor installation shall be carried out by appropriately qualified personnel and under the supervision of the person responsible for technical matters of the site.
- Installation shall be executed in temperature from -20°C to +40°C.
- Exposure to UV due to solar radiation of the anchor not protected by the mortar shall not exceed $\leq$ 6 weeks.

**KPR-FAST, KPS-FAST, KPR/FAST, KPS/FAST,
KPR-STRONG and KPS-STRONG**

**Intended use
Specifications**

**Annex B1
of European
Technical Assessment
ETA-12/0272**

Table B1: Installation parameters

Anchor type		KPR-FAST 8/50 KPS-FAST 8/50	KPR-FAST 8/70 KPS-FAST 8/70	KPR/FAST 10 KPS/FAST 10 KPR-FAST 10/70 KPS-FAST 10/70 KPR-STRONG 10 KPS-STRONG 10	KPR-FAST 10/50 KPS-FAST 10/50	KPR-FAST 12 KPS-FAST 12	KPR-FAST 14 KPS-FAST 14
Drill hole diameter	d_o [mm]	8	8	10	10	12	14
Cutting diameter of drill bit	$d_{cut} \leq$ [mm]	8.45	8.45	10.45	10.45	12.45	14.45
Depth of drill hole to deepest point	$h_1 \geq$ [mm]	60	80	80	60	80	85
Overall plastic anchor embedment depth in the base material	$h_{nom} \geq$ [mm]	50	70	70	50	70	70
Diameter of clearance hole in the fixture	$d_f \leq$ [mm]	8.5 - 9.0	8.5 - 9.0	10.5 - 11.0	10.5 - 11.0	12.5 - 13.0	14.5 - 15.0
Thickness of fixture – minimum	$t_{fix, min} \geq$ [mm]	1	1	1	1	1	1
Thickness of fixture – maximum	$t_{fix, max} \leq$ [mm]	170	150	230	250	290	290
Installation temperature	°C	-20 to +40					
Torque moment for concrete and masonry	T_{inst} [Nm]	7	7	15	15	30	50
Torque moment for AAC	T_{inst} [Nm]	3	3	5	5	13	18

**KPR-FAST, KPS-FAST, KPR/FAST, KPS/FAST,
KPR-STRONG and KPS-STRONG**

Intended use
Installation parameters

Annex B2
of European
Technical Assessment
ETA-12/0272

Table B2: Minimum thickness of member, edge distance and spacing in concrete


Anchor type	Base material	h_{min} [mm]	$C_{cr, N}$ [mm]	$S_{cr, N}$ [mm]	C_{min} [mm]	S_{min} [mm]
KPR-FAST 8/50 KPS-FAST 8/50	Concrete $\geq$ C16/20	100	70	70	50	50
	Concrete $\geq$ C12/15	100	100	95	70	70
KPR-FAST 8/70 KPS-FAST 8/70	Concrete $\geq$ C16/20	100	100	80	60	60
	Concrete $\geq$ C12/15	100	140	115	80	80
KPR/FAST 10 KPS/FAST 10	Concrete $\geq$ C16/20	100	100	75	60	60
	Concrete $\geq$ C12/15	100	140	105	80	80
KPR-FAST10/50 KPS-FAST10/50	Concrete $\geq$ C16/20	100	100	75	50 for $s \geq 150$ mm	50 for $c \geq 100$ mm
	Concrete $\geq$ C12/15	100	140	105	70 for $s \geq 210$ mm	70 for $c \geq 140$ mm
	Thin wall concrete elements $\geq$ C16/20	30	100	100	100	100
KPR-FAST10/70 KPS-FAST10/70	Concrete $\geq$ C16/20	100	100	110	50 for $s \geq 150$ mm	50 for $c \geq 100$ mm
	Concrete $\geq$ C12/15	100	140	150	70 for $s \geq 210$ mm	70 for $c \geq 150$ mm
	Thin wall concrete elements $\geq$ C16/20	30	100	100	100	100
KPR-FAST 12 KPS-FAST 12	Concrete $\geq$ C16/20	100	100	85	100	100
	Concrete $\geq$ C12/15	100	140	120	140	140
KPR-FAST 14 KPS-FAST 14	Concrete $\geq$ C16/20	100	100	115	100	100
	Concrete $\geq$ C12/15	100	140	160	140	140

**KPR-FAST, KPS-FAST, KPR/FAST, KPS/FAST,
KPR-STRONG and KPS-STRONG**


Intended use
Minimum thickness of member, edge distance and spacing in concrete

Annex B3
of European
Technical Assessment
ETA-12/0272

Scheme of edge distance and spacing in concrete



Scheme of edge distance and spacing in thin-wall concrete elements



**KPR-FAST, KPS-FAST, KPR/FAST, KPS/FAST,
KPR-STRONG and KPS-STRONG**

Intended use


Minimum thickness of member, edge distance and spacing in concrete

Annex B3
of European
Technical Assessment
ETA-12/0272

Table B3: Minimum thickness of member, edge distance and spacing in masonry

Anchor diameter	Base material	Type of element	Single anchor			Anchor group ¹⁾	
			h_{min} [mm]	c_{min} [mm]	s_{min} [mm]	$s_{min1}^{2)}$ [mm]	$s_{min2}^{3)}$ [mm]
$\phi 8$	masonry made of ceramic, calcium silicate and lightweight aggregate concrete elements	solid	120	100	100	100	200
		perforated or hollow	180	100	100	100	200
	masonry made of autoclaved aerated concrete elements	—	100	100	100	100	200
$\phi 10$	masonry made of ceramic, calcium silicate and lightweight aggregate concrete elements	solid	120	100	100	100	200
		perforated or hollow	180	100	100	100	200
	masonry made of autoclaved aerated concrete elements	—	100	100	100	100	200
$\phi 12$	masonry made of ceramic, calcium silicate and lightweight aggregate concrete elements	solid	120	100	100	100	200
		perforated or hollow	180	100	100	100	200
	masonry made of autoclaved aerated concrete elements	—	100	100	100	100	200
$\phi 14$	masonry made of ceramic, calcium silicate and lightweight aggregate concrete elements	solid	120	100	100	100	200
		perforated or hollow	180	100	100	100	200
	masonry made of autoclaved aerated concrete elements	—	100	100	100	100	200

¹⁾ the design method valid for single anchor and anchor groups with two or four anchors
²⁾ in direction perpendicular to free edge
³⁾ in direction parallel to free edge

Scheme of edge distance and spacing in masonry

**KPR-FAST, KPS-FAST, KPR/FAST, KPS/FAST,
KPR-STRONG and KPS-STRONG**

Intended use
Minimum thickness of member, edge distance and spacing in masonry

Annex B4
of European
Technical Assessment
ETA-12/0272




	Drill the hole considering the drilling method and clean the hole of drilling dust.
	Insert the plastic sleeve and special screw into the hole through the fixture by slight hammer blows.
	Screw-in the special screw until the head of the screw touches the sleeve; the anchor is correct mounted, if there is no turn-through of the plastic sleeve in the drill hole and if slightly move on turning of the screw is impossible.
KPR-FAST, KPS-FAST, KPR/FAST, KPS/FAST, KPR-STRONG and KPS-STRONG	Annex B5 of European Technical Assessment ETA-12/0272
Intended use Installation instruction	

Table C1.1: Characteristic bending resistance of the specific screw in concrete and masonry

Anchor diameter		φ8	φ10	φ12	φ14
Characteristic bending resistance	$M_{Rk,s}$ [Nm]	10.5 ¹⁾ (10.2) ²⁾	16.8 ¹⁾ (16.3) ²⁾	16.2 ¹⁾ (23.4) ²⁾	34.4 ¹⁾ (49.8) ²⁾
Partial safety factor	γ_{Ms} ³⁾	1.25 ¹⁾ / 1.29 ²⁾	1.25 ¹⁾ / 1.29 ²⁾	1.25 ¹⁾ / 1.29 ²⁾	1.25 ¹⁾ / 1.29 ²⁾
¹⁾ galvanised steel ²⁾ stainless steel ³⁾ in the absence of other national regulations					

Table C1.2: Characteristic resistance of the screw for use in concrete – failure of expansion element (specific screw)

Anchor diameter		φ8	φ10	φ12	φ14
Characteristic tension resistance	$N_{Rk,s}$ [kN]	13.2 ¹⁾ (12.8) ²⁾	18.1 ¹⁾ (17.5) ²⁾	15.4 ¹⁾ (22.3) ²⁾	25.4 ¹⁾ (36.9) ²⁾
Partial safety factor	γ_{Ms} ³⁾	1.50 ¹⁾ / 1.55 ²⁾	1.50 ¹⁾ / 1.55 ²⁾	1.50 ¹⁾ / 1.55 ²⁾	1.50 ¹⁾ / 1.55 ²⁾
Characteristic shear resistance	$V_{Rk,s}$ [kN]	6.6 ¹⁾ (6.4) ²⁾	9.1 ¹⁾ (8.8) ²⁾	7.70 ¹⁾ (11.2) ²⁾	12.7 ¹⁾ (18.4) ²⁾
Partial safety factor	γ_{Ms} ³⁾	1.25 ¹⁾ / 1.29 ²⁾	1.25 ¹⁾ / 1.29 ²⁾	1.25 ¹⁾ / 1.29 ²⁾	1.25 ¹⁾ / 1.29 ²⁾
¹⁾ galvanised steel ²⁾ stainless steel ³⁾ in the absence of other national regulations					

**KPR-FAST, KPS-FAST, KPR/FAST, KPS/FAST,
KPR-STRONG and KPS-STRONG**

Performances
Characteristic resistance of the screw

Annex C1
of European
Technical Assessment
ETA-12/0272

Table C2.1: Characteristic resistance for use in concrete, pull-out failure (plastic sleeve); hammer drilling

Anchor type	KPR-FAST 8/50 KPS-FAST 8/50	KPR-FAST 8/70 KPS-FAST 8/70	KPR/FAST 10 KPS/FAST 10	KPR-FAST 10/50 KPS-FAST 10/50	KPR-FAST 10/70 KPS-FAST 10/70	KPR-STRONG 10 KPS-STRONG 10	KPR-FAST 12 KPS-FAST 12	KPR-FAST 14 KPS-FAST 14
Temperature range [°C]	-20 to +80							
Concrete ≥ C16/20								
Characteristic resistance $N_{Rk,p}$ [kN]	3.5	4.5	4.0	4.0	8.5	6.0	5.0	7.5
Partial safety factor $\gamma_{Mc}^{1)}$	1.8							
Concrete C12/15								
Characteristic resistance $N_{Rk,p}$ [kN]	2.5	3.0	3.0	3.0	6.0	4.5	3.5	5.0
Partial safety factor $\gamma_{Mc}^{1)}$	1.8							
Thin-wall concrete elements C16/20, h ≥ 30 mm								
Characteristic resistance $N_{Rk,p}$ [kN]	-	-	-	4.0	4.0	-	-	-
Partial safety factor $\gamma_{Mc}^{1)}$	1.8							
1) in the absence of other national regulations								

**KPR-FAST, KPS-FAST, KPR/FAST, KPS/FAST,
KPR-STRONG and KPS-STRONG**

Performances
Characteristic resistance in concrete (base material group a)

Annex C2
of European
Technical Assessment
ETA-12/0272

Table C3.1: Displacements under tension and shear loading in concrete ^{1), 2)}

Anchor type	Tension load			Shear load		
	F [kN]	δ_{No} [mm]	$\delta_{N\infty}$ [mm]	F [kN]	δ_{No} [mm]	$\delta_{N\infty}$ [mm]
KPR-FAST 8/50 KPS-FAST 8/50	1.4	0.34	0.68	3.7	3.16	4.74
KPR-FAST 8/70 KPS-FAST 8/70	1.78	0.29	0.58	3.7	3.16	4.74
KPR-FAST 10 KPS-FAST 10	1.6	0.26	0.73	7.2	3.6	5.39
KPR-FAST 10 KPS-FAST 10 STRONG	2.38	0.35	0.7	7.2	3.6	5.39
KPR-FAST 12 KPS-FAST 12	1.98	0.37	0.55	8.29	3.83	5.74
KPR-FAST 14 KPS-FAST 14	3.0	0.31	0.86	12.91	5.77	8.65
KPR-FAST 10/50 KPS-FAST 10/50	1.6	0.3	0.6	7.2	3.6	5.39
KPR-FAST 10/70 KPS-FAST 10/70	3.37	0.3	0.6	7.2	3.6	5.39

¹⁾ valid for all ranges of temperatures
²⁾ intermediate values by linear interpolation

Table C3.2: Characteristic values F_{Rk} in any load direction under fire exposure in concrete C20/25 to C50/60, no permanent centric tension load and shear load with lever arm, for fixing of façade systems

Anchor type	Fire resistance class	F_{Rk} , kN
KPR-FAST 10, KPS-FAST 10 KPR-STRONG 10, KPS-STRONG 10 KPR-FAST 10, KPS-FAST 10	R 90	0.8



**KPR-FAST, KPS-FAST, KPR-FAST, KPS-FAST,
KPR-STRONG and KPS-STRONG**

Performances

Characteristic resistance in concrete (base material group a),
displacements in concrete, resistance to fire

Annex C3
of European
Technical Assessment
ETA-12/0272

Table C4.1: Characteristic resistance for use in masonry

Anchor type / Base material	Bulk density class [kg/dm ³]	Mean compressive strength class [N/mm ²]	Picture	Drill method	F _{Rk} ¹⁶⁾ [kN]
KPR-FAST 8/50 and KPS-FAST 8/50					
Clay brick ^{1), 6)}	≥ 2.00	≥ 10		hammer	3.0
Clay brick ^{1), 6)}	≥ 2.00	≥ 20		hammer	3.0
Calcium silicate brick ^{2), 7)}	≥ 2.00	≥ 20		hammer	3.0
KPR-FAST 8/70 and KPS-FAST 8/70					
Clay brick ^{1), 6)}	≥ 2.00	≥ 10		hammer	2.5
Clay brick ^{1), 6)}	≥ 2.00	≥ 20		hammer	3.0
Calcium silicate brick ^{2), 7)}	≥ 2.00	≥ 20		hammer	3.0
Perforated ceramic brick ^{1), 9)}	≥ 0.80	≥ 15		rotary drilling only	1.2
Perforated ceramic brick ^{1), 10)}	≥ 0.80	≥ 15		rotary drilling only	1.2
Calcium silicate hollow block ^{2), 12)}	≥ 1.60	≥ 12		rotary drilling only	2.5
Hollow lightweight aggregate concrete element ^{3), 13)}	≥ 0.80	≥ 2		rotary drilling only	2.0
Autoclaved aerated concrete element AAC 2 ⁴⁾	≥ 0.35	≥ 2		rotary drilling only	0.6
Autoclaved aerated concrete element AAC 7 ⁴⁾	≥ 0.65	≥ 6.5		rotary drilling only	2.0






**KPR-FAST, KPS-FAST, KPR/FAST, KPS/FAST,
KPR-STRONG and KPS-STRONG**

Performances

Characteristic resistance in masonry (base material group b, c and d)

Annex C4
of European
Technical Assessment
ETA-12/0272

extension of Table C4.1

Anchor type / Base material	Bulk density class [kg/dm ³]	Mean compressive strength class [N/mm ²]	Picture	Drill method	F _{FRK} ⁽¹⁶⁾ [kN]
KPR/FAST 10 and KPS/FAST 10					
Clay brick ^{1), 5)}	≥ 1.70	≥ 10		hammer	3.5
Clay brick ^{1), 5)}	≥ 1.70	≥ 20		hammer	3.5
Clay brick ^{1), 6)}	≥ 2.00	≥ 10		hammer	3.5
Clay brick ^{1), 6)}	≥ 2.00	≥ 20		hammer	3.5
Calcium silicate brick ^{2), 7)}	≥ 2.00	≥ 20		hammer	3.5
Perforated ceramic brick ^{1), 9)}	≥ 0.80	≥ 15		rotary drilling only	0.9
Perforated ceramic brick ^{1), 10)}	≥ 0.80	≥ 15		rotary drilling only	0.9
Perforated ceramic brick ^{1), 11)}	≥ 1.20	≥ 12		rotary drilling only	2.0
Calcium silicate hollow block ^{2), 12)}	≥ 1.60	≥ 12		rotary drilling only	2.5
Hollow lightweight aggregate concrete element ^{3), 13)}	≥ 0.80	≥ 2		rotary drilling only	2.0
Autoclaved aerated concrete element AAC 2 ⁴⁾	≥ 0.35	≥ 2	—	rotary drilling only	0.6
Autoclaved aerated concrete element AAC 7 ⁴⁾	≥ 0.65	≥ 6.5		rotary drilling only	1.5
KPR-STRONG 10 and KPS-STRONG 10					
Clay brick ^{1), 6)}	≥ 2.00	≥ 10		hammer	3.5
Clay brick ^{1), 6)}	≥ 2.00	≥ 20		hammer	3.5
Calcium silicate brick ^{2), 7)}	≥ 2.00	≥ 20		hammer	3.5




**KPR-FAST, KPS-FAST, KPR/FAST, KPS/FAST,
KPR-STRONG and KPS-STRONG**

Performances

Characteristic resistance in masonry (base material group b, c and d)

Annex C4
of European
Technical Assessment
ETA-12/0272

extension of Table C4.1

Anchor type / Base material	Bulk density class [kg/dm ³]	Mean compressive strength class [N/mm ²]	Picture	Drill method	F _{Rk} ¹⁶⁾ [kN]
KPR-FAST 10/50 and KPS-FAST 10/50					
Clay brick ^{1), 5)}	≥ 1.70	≥ 10		hammer	1.5
Clay brick ^{1), 5)}	≥ 1.70	≥ 20		hammer	2.0
Clay brick ^{1), 6)}	≥ 2.00	≥ 10		hammer	2.0
Clay brick ^{1), 6)}	≥ 2.00	≥ 20		hammer	3.0
Calcium silicate brick ^{2), 7)}	≥ 2.00	≥ 20		hammer	3.0
Perforated ceramic brick ^{1), 8)}	≥ 0.80	≥ 15		rotary	1.2
Perforated ceramic brick ^{1), 9)}	≥ 0.80	≥ 15		rotary	2.5
Perforated ceramic brick ^{1), 10)}	≥ 0.80	≥ 15		rotary	2.5
Perforated ceramic brick ^{1), 11)}	≥ 1.20	≥ 12		rotary	1.5
Calcium silicate hollow block ^{2), 12)}	≥ 1.60	≥ 12		rotary	2.5
Lightweight concrete blocks ³⁾	≥ 0.80	≥ 2		rotary	1.5
Aggregate concrete masonry units ^{3), 14)}	≥ 1.5	≥ 25		rotary	3.5
Aggregate concrete masonry units ^{3), 15)}	≥ 1.0	≥ 20		rotary	4.0





**KPR-FAST, KPS-FAST, KPR/FAST, KPS/FAST,
KPR-STRONG and KPS-STRONG**

Performances

Characteristic resistance in masonry (base material group b, c and d)

Annex C4
of European
Technical Assessment
ETA-12/0272

extension of Table C4.1

Anchor type / Base material	Bulk density class [kg/dm ³]	Mean compressive strength class [N/mm ²]	Picture	Drill method	F _{RK} ¹⁶⁾ [kN]
KPR-FAST 10/70 and KPS-FAST 10/70					
Clay brick ^{1), 5)}	≥ 1.70	≥ 10		hammer	2.0
Clay brick ^{1), 5)}	≥ 1.70	≥ 20		hammer	3.5
Clay brick ^{1), 6)}	≥ 2.00	≥ 10		hammer	2.0
Clay brick ^{1), 6)}	≥ 2.00	≥ 20		hammer	3.0
Calcium silicate brick ^{2), 7)}	≥ 2.00	≥ 20		hammer	3.0
Perforated ceramic brick ^{1), 8)}	≥ 0.80	≥ 15		rotary	1.0
Perforated ceramic brick ^{1), 9)}	≥ 0.80	≥ 15		rotary	1.0
Perforated ceramic brick ^{1), 10)}	≥ 0.80	≥ 15		rotary	1.0
Perforated ceramic brick ^{1), 11)}	≥ 1.20	≥ 12		rotary	1.5
Calcium silicate hollow block ^{2), 12)}	≥ 1.60	≥ 12		rotary	2.5
Lightweight concrete blocks ³⁾	≥ 0.80	≥ 2		rotary	1.5
Aggregate concrete masonry units ^{3), 14)}	≥ 1.5	≥ 25		rotary	3.5
Aggregate concrete masonry units ^{3), 15)}	≥ 1.0	≥ 20		rotary	4.0
Autoclaved aerated concrete element AAC 2 ⁴⁾	≥ 0.35	≥ 2	—	rotary	0.9
Autoclaved aerated concrete element AAC 7 ⁴⁾	≥ 0.65	≥ 6.5	—	rotary	2.0






**KPR-FAST, KPS-FAST, KPR/FAST, KPS/FAST,
KPR-STRONG and KPS-STRONG**

Performances

Characteristic resistance in masonry (base material group b, c and d)

Annex C4
of European
Technical Assessment
ETA-12/0272

extension of Table C4.1

Anchor type / Base material	Bulk density class [kg/dm ³]	Mean compressive strength class [N/mm ²]	Picture	Drill method	F _{RK} ¹⁶⁾ [kN]
KPR-FAST 12 and KPS-FAST 12					
Clay brick ^{1), 5)}	≥ 1.70	≥ 10		hammer	2.5
Clay brick ^{1), 5)}	≥ 1.70	≥ 20		hammer	3.5
Clay brick ^{1), 6)}	≥ 2.00	≥ 10		hammer	3.5
Clay brick ^{1), 6)}	≥ 2.00	≥ 20		hammer	3.5
Calcium silicate brick ^{2), 7)}	≥ 2.00	≥ 20		hammer	3.5
Perforated ceramic brick ^{1), 11)}	≥ 1.20	≥ 12		rotary	2.0
Calcium silicate hollow block ^{2), 12)}	≥ 1.60	≥ 12		rotary	3.0
Hollow lightweight aggregate concrete element ^{3), 13)}	≥ 0.80	≥ 2		rotary	2.0
Autoclaved aerated concrete element AAC 2 ⁴⁾	≥ 0.35	≥ 2	—	rotary	0.75
Autoclaved aerated concrete element AAC 7 ⁴⁾	≥ 0.65	≥ 6.5	—	rotary	3.0




**KPR-FAST, KPS-FAST, KPR/FAST, KPS/FAST,
KPR-STRONG and KPS-STRONG**

Performances

Characteristic resistance in masonry (base material group b, c and d)

Annex C4
of European
Technical Assessment
ETA-12/0272

extension of Table C4.1

Anchor type / Base material	Bulk density class [kg/dm ³]	Mean compressive strength class [N/mm ²]	Picture	Drill method	F _{Rk} ¹⁶⁾ [kN]
KPR-FAST 14 and KPS-FAST 14					
Clay brick ^{1), 5)}	≥ 1.70	≥ 10		hammer	4.0
Clay brick ^{1), 5)}	≥ 1.70	≥ 20		hammer	4.0
Clay brick ^{1), 6)}	≥ 2.00	≥ 10		hammer	4.0
Clay brick ^{1), 6)}	≥ 2.00	≥ 20		hammer	4.0
Calcium silicate brick ^{2), 7)}	≥ 2.00	≥ 20		hammer	4.0
Perforated ceramic brick ^{1), 11)}	≥ 1.20	≥ 12		rotary	2.0
Calcium silicate hollow block ^{2), 12)}	≥ 1.60	≥ 12		rotary	3.5
Hollow lightweight aggregate concrete element ^{3), 13)}	≥ 0.80	≥ 2		rotary	2.0
Autoclaved aerated concrete element AAC 2 ⁴⁾	≥ 0.35	≥ 2	—	rotary	0.9
Autoclaved aerated concrete element AAC 7 ⁴⁾	≥ 0.65	≥ 6.5	—	rotary	3.0
Partial safety factor γ _{Mm} ¹⁷⁾	2.5 / 2.0				
¹⁾ According to EN 771-1 ²⁾ According to EN 771-2 ³⁾ According to EN 771-3 ⁴⁾ According to EN 771-4 ⁵⁾ Polish clay brick; (L x W x H) = 250 x 120 x 65 mm ⁶⁾ German clay brick MZ Rd 2.0/20; (L x W x H) = 250 x 120 x 65 mm ⁷⁾ For example Kalksandstein KS NF 20-2.0 Vollstein according to DIN 106; (L x W x H) = 250 x 115 x 71 mm ⁸⁾ For example Porotherm 18.8; (L x W x H) = 468 x 188 x 238 mm ⁹⁾ For example Porotherm 25 P+W; (L x W x H) = 250 x 373 x 238 mm ¹⁰⁾ For example MAX 250; (L x W x H) = 250 x 373 x 238 mm ¹¹⁾ For example HLZ Rd1 1.2/12 according to DIN 105; (L x W x H) = 308 x 240 x 238 mm ¹²⁾ For example KSL-R(P)8DF Lochstein according to DIN 106; (L x W x H) = 498 x 115 x 245 mm ¹³⁾ For example Hbl 2/0.8 Leichtbetonhohlstein according to DIN 18 151-100; (L x W x H) = 365 x 247 x 238 mm ¹⁴⁾ For example TeknoAmerBlok PK17.8; (L x W x H) = 178 x 390 x 190 mm ¹⁵⁾ For example TeknoAmerBlok PK19; (L x W x H) = 190 x 390 x 190 mm ¹⁶⁾ Characteristic resistance F_{Rk} for tension, shear or combined tension and shear loading. The characteristic resistance is valid for single plastic anchor or for a group of two or four plastic anchors with a spacing equal or larger than the minimum spacing s_{min} according to Table B3 (Annex B4). ¹⁷⁾ Partial safety factor for use in masonry γ_{Mm} = 2,5 and partial safety factor for use in autoclaved aerated concrete γ_{MAAC} = 2,0 in absence of other national regulations.					

**KPR-FAST, KPS-FAST, KPR/FAST, KPS/FAST,
KPR-STRONG and KPS-STRONG**

Performances

Characteristic resistance in masonry (base material group b, c and d)

Annex C4
of European
Technical Assessment
ETA-12/0272

Table C5.1: Displacements under tension and shear loading in masonry

Anchor type	Base material	Tension load			Shear load		
		F [kN]	δ_{NO} [mm]	δ_{N^∞} [mm]	F [kN]	δ_{NO} [mm]	δ_{N^∞} [mm]
KPR-FAST 8/50 KPS-FAST 8/50	Clay brick ^{1), 6)}	0.86	1.71	3.42	0.86	1.71	3.42
	Calcium silicate brick ^{3), 7)}	0.86	0.19	0.38	0.86	0.19	0.38
KPR-FAST 8/70 KPS-FAST 8/70	Clay brick ^{1), 6)}	0.86	0.35	0.70	0.86	0.35	0.70
	Calcium silicate brick ^{2), 7)}	0.86	0.20	0.40	0.86	0.20	0.40
	Perforated ceramic brick ^{1), 9)}	0.34	0.23	0.46	0.34	0.23	0.46
	Perforated ceramic brick ^{1), 10)}	0.34	0.23	0.46	0.34	0.23	0.46
	Calcium silicate hollow block ^{2), 12)}	0.71	0.31	0.62	0.71	0.31	0.62
	Hollow lightweight aggregate concrete element ^{3), 13)}	0.43	1.10	2.20	0.57	1.10	2.20
	Autoclaved aerated concrete element AAC 2 ⁴⁾	0.21	0.42	0.84	0.21	0.42	0.84
	Autoclaved aerated concrete element AAC 7 ⁴⁾	0.71	0.30	0.60	0.71	0.30	0.60

**KPR-FAST, KPS-FAST, KPR/FAST, KPS/FAST,
KPR-STRONG and KPS-STRONG**

Performances
Displacements in masonry

Annex C5
of European
Technical Assessment
ETA-12/0272

extension of Table C5.1

Anchor type	Base material	Tension load			Shear load		
		F [kN]	δ_{NO} [mm]	$\delta_{N^{\infty}}$ [mm]	F [kN]	δ_{NO} [mm]	$\delta_{N^{\infty}}$ [mm]
KPR/FAST 10 KPS/FAST 10	Clay brick ^{1), 5)}	1.00	0.20	0.40	1.00	0.83	1.25
	Clay brick ^{1), 6)}	1.00	1.07	2.13	1.00	0.83	1.25
	Calcium silicate brick ^{3), 7)}	1.00	0.09	0.18	1.00	0.83	1.25
	Perforated ceramic brick ^{1), 9)}	0.30	0.73	1.46	0.26	0.51	0.77
	Perforated ceramic brick ^{1), 10)}	0.30	0.73	1.46	0.26	0.51	0.77
	Perforated ceramic brick ^{1), 11)}	0.60	1.38	2.75	0.57	1.14	1.71
	Calcium silicate hollow block ^{2), 12)}	0.70	0.55	1.09	0.71	1.43	2.14
	Hollow lightweight aggregate concrete element ^{3), 13)}	0.43	1.35	2.70	0.57	1.14	1.71
	Autoclaved aerated concrete element AAC 2 ⁴⁾	0.20	0.15	0.29	0.21	0.43	0.64
	Autoclaved aerated concrete element AAC 7 ⁴⁾	0.50	0.02	0.04	0.54	1.07	1.61
KPR-STRONG 10 KPS-STRONG 10	Clay brick ^{1), 6)}	1.00	1.10	2.20	1.00	0.83	1.25
	Calcium silicate brick ^{2), 7)}	1.00	0.15	0.30	1.00	0.83	1.25

KPR-FAST, KPS-FAST, KPR/FAST, KPS/FAST,
KPR-STRONG and KPS-STRONG

Performances
Displacements in masonry

Annex C5
of European
Technical Assessment
ETA-12/0272

extension of Table C5.1

Anchor type	Base material	Tension load			Shear load		
		F [kN]	δ_{NO} [mm]	δ_{N^∞} [mm]	F [kN]	δ_{NO} [mm]	δ_{N^∞} [mm]
KPR-FAST 10/50 KPS-FAST 10/50	Clay brick ^{1), 5)}	0.6	0.1	0.2	0.6	0.9	0.6
	Clay brick ^{1), 6)}	0.9	0.5	1.0	0.7	1.1	0.7
	Calcium silicate brick ^{3), 7)}	0.9	0.3	0.6	0.7	1.1	0.7
	Perforated ceramic brick ^{1), 8)}	0.7	0.6	1.2	0.7	0.6	0.9
	Perforated ceramic brick ^{1), 9)}	0.7	1.0	2.0	0.7	0.5	0.8
	Perforated ceramic brick ^{1), 10)}	0.7	1.0	2.0	0.7	0.5	0.8
	Perforated ceramic brick ^{1), 11)}	0.4	0.5	1.0	0.4	0.4	0.6
	Calcium silicate hollow block ^{2), 12)}	0.7	0.6	1.2	0.7	0.5	0.8
	Lightweight concrete blocks ³⁾	0.4	1.1	2.2	0.4	1.0	1.5
	Aggregate concrete masonry units ^{3), 14)}	1.0	0.4	0.8	1.0	0.5	0.75
	Aggregate concrete masonry units ^{3), 15)}	1.1	0.4	0.8	1.1	0.5	0.75

KPR-FAST, KPS-FAST, KPR/FAST, KPS/FAST,
KPR-STRONG and KPS-STRONG

Performances
Displacements in masonry

Annex C5
of European
Technical Assessment
ETA-12/0272

extension of Table C5.1

Anchor type	Base material	Tension load			Shear load		
		F [kN]	δ_{NO} [mm]	$\delta_{N\infty}$ [mm]	F [kN]	δ_{NO} [mm]	$\delta_{N\infty}$ [mm]
KPR-FAST 10/70 KPS-FAST 10/70	Clay brick ^{1), 5)}	1.0	0.3	0.6	1.0	0.8	1.2
	Clay brick ^{1), 6)}	0.9	0.8	1.6	0.9	0.7	1.1
	Calcium silicate brick ^{3), 7)}	0.9	0.2	0.4	0.9	0.7	1.1
	Perforated ceramic brick ^{1), 8)}	0.3	0.5	1.0	0.3	0.4	0.6
	Perforated ceramic brick ^{1), 9)}	0.3	0.6	1.2	0.3	0.4	0.6
	Perforated ceramic brick ^{1), 10)}	0.3	0.6	1.2	0.3	0.4	0.6
	Perforated ceramic brick ^{1), 11)}	0.4	0.6	1.2	0.4	0.4	0.6
	Calcium silicate hollow block ^{2), 12)}	0.7	0.7	1.4	0.7	1.4	2.1
	Lightweight concrete blocks ³⁾	0.4	1.0	2.0	0.4	1.0	1.5
	Autoclaved aerated concrete element AAC 2 ⁴⁾	0.3	0.2	0.4	0.3	0.5	0.8
	Autoclaved aerated concrete element AAC 7 ⁴⁾	0.7	0.3	0.6	0.7	0.7	1.1
	Aggregate concrete masonry units ^{3), 14)}	1.0	0.4	0.8	1.0	0.5	0.75
	Aggregate concrete masonry units ^{3), 15)}	1.1	0.4	0.8	1.1	0.6	0.9

KPR-FAST, KPS-FAST, KPR/FAST, KPS/FAST,
KPR-STRONG and KPS-STRONG

Performances
Displacements in masonry

Annex C5
of European
Technical Assessment
ETA-12/0272

extension of Table C5.1

Anchor type	Base material	Tension load			Shear load		
		F [kN]	δ_{NO} [mm]	δ_{N^∞} [mm]	F [kN]	δ_{NO} [mm]	δ_{N^∞} [mm]
KPR-FAST 12 KPS-FAST 12	Clay brick ^{1), 5)}	1.00	0.36	0.72	1.00	0.83	1.25
	Clay brick ^{1), 6)}	1.00	0.27	0.54	1.00	0.83	1.25
	Calcium silicate brick ^{2), 7)}	1.00	0.28	0.56	1.00	0.83	1.25
	Perforated ceramic brick ^{1), 11)}	0.57	0.72	1.44	0.57	1.14	1.71
	Calcium silicate hollow block ^{2), 12)}	0.86	0.43	0.86	0.86	1.71	2.57
	Hollow lightweight aggregate concrete element ^{3), 13)}	0.43	0.06	0.12	0.57	1.14	1.71
	Autoclaved aerated concrete element AAC 2 ⁴⁾	0.27	0.39	0.78	0.27	0.54	0.80
	Autoclaved aerated concrete element AAC 7 ⁴⁾	1.07	0.36	0.72	1.07	2.14	3.21
KPR-FAST 14 KPS-FAST 14	Clay brick ^{1), 5)}	1.14	0.28	0.56	1.14	0.95	1.43
	Clay brick ^{1), 6)}	1.14	0.27	0.54	1.14	0.95	1.43
	Calcium silicate brick ^{2), 7)}	1.14	0.09	0.18	1.14	0.95	1.43
	Perforated ceramic brick ^{1), 11)}	0.57	0.13	0.26	0.57	1.14	1.71
	Calcium silicate hollow block ^{2), 12)}	1.00	0.16	0.32	1.00	2.00	3.00
	Hollow lightweight aggregate concrete element ^{3), 13)}	0.57	0.09	0.18	0.57	1.14	1.71
	Autoclaved aerated concrete element AAC 2 ⁴⁾	0.32	0.39	0.78	0.32	0.64	0.96
	Autoclaved aerated concrete element AAC 7 ⁴⁾	1.07	0.17	0.34	1.07	2.14	3.21
¹⁾ According to EN 771-1 ²⁾ According to EN 771-2 ³⁾ According to EN 771-3 ⁴⁾ According to EN 771-4 ⁵⁾ Polish clay brick; (L x W x H) = 250 x 120 x 65 mm ⁶⁾ German clay brick MZ Rd 2.0/20; (L x W x H) = 250 x 120 x 65 mm ⁷⁾ For example Kalksandstein KS NF 20-2.0 Vollstein according to DIN 106; (L x W x H) = 250 x 115 x 71 mm ⁸⁾ For example Porothersm 18.8; (L x W x H) = 468 x 188 x 238 mm ⁹⁾ For example Porothersm 25 P+W; (L x W x H) = 250 x 373 x 238 mm ¹⁰⁾ For example MAX 250; (L x W x H) = 250 x 373 x 238 mm ¹¹⁾ For example HLZ Rd1 1.2/12 according to DIN 105; (L x W x H) = 308 x 240 x 238 mm ¹²⁾ For example KSL-R(P)8DF Lochstein according to DIN 106; (L x W x H) = 498 x 115 x 245 mm ¹³⁾ For example Hbl 2/0.8 Leichtbetonhohlstein according to DIN 18 151-100; (L x W x H) = 365 x 247 x 238 mm ¹⁴⁾ For example TeknoAmerBlok PK17,8; (L x W x H) = 178 x 390 x 190 mm ¹⁵⁾ For example TeknoAmerBlok PK19; (L x W x H) = 190 x 390 x 190 mm							

**KPR-FAST, KPS-FAST, KPR/FAST, KPS/FAST,
KPR-STRONG and KPS-STRONG**

Performances
Displacements in masonry

Annex C5
of European
Technical Assessment
ETA-12/0272